

DECLARATION OF CONFORMITY

ET2011 Series

This product is manufactured at the premises of West Control Solutions, The Hyde Business Park, Brighton, East Sussex, BN2 4JU, England, UK

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The objects of this declaration are the products identified using the model numbers derived from the tables listed below.

The objects of this declaration are in conformity with the following European Union harmonisation legislation:

2014/30/EU Electromagnetic Compatibility

2014/35/EU Low Voltage Directive

2011/65/EU Restriction of Hazardous Substances in Electrical and Electronic Equipment

The assessment of conformity has been made using the standards route to compliance. The standards this product is compliant with are listed below: -

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use — EMC Requirements — Part 1: General Requirements

This product has been evaluated as Class A equipment suitable for operation in Industrial Locations against this standard.

WARNING

This is a Class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

EN 61010-1:2010, Safety requirements for electrical equipment for measurement, control and laboratory use.

This declaration is made for and on behalf of Fortive by Paul Barber, who has been designated as the responsible person for the purpose of the regulations.

Signature:



(Paul Barber)

Date of Issue:

25 February 2020

Order Code	ET2011	-	xx	-	xxx	-	x	-	X
Sensor Type									
PT100/RTD			RT						
Thermocouple			T						
Power supply input									
230VAC					230				
110VAC					110				
24VAC					024				
9 - 30VDC / 7-24VAC					SM				
Power Relay Option									
8A relay									
16A relay							P		
Temperature Unit									
Celcius									
Fahrenheit									F